

**Hardwicke Planning Group - Review of Planning Application - S.18/2339/DISCON -  
Discharge of condition 10 from permission S.15/1498/VAR - Hunts Grove Parcel R22  
Harrier Way Hardwicke Gloucester**

1 The application is a request for discharge of S.15/1498/VAR condition 10 that states '*...10. The dwellings hereby permitted shall be constructed to provide the necessary noise mitigation to achieve internal noise levels within bedrooms and living rooms no greater than 35 dB (LAeq,T) during the daytime (07:00 – 23:00) and within bedrooms no greater than 30 dB (LAeqT) during night-time (23:00 – 07:00) periods. An external noise level of 50 dB (LAeq,T) should not be exceeded in private garden areas and patios during the daytime period. After completion of works and prior to occupation or use, noise measurements shall be carried out to demonstrate that the above criteria are met. All noise measurements shall be submitted in the form of a report to the LPA for its written approval prior to occupation or use.*

*Reason: To protect residential amenity...'*

2 Hardwicke Parish Council Planning Group reviewed the application as of 2<sup>nd</sup> December 2018.

3 There is no evidence offered to support the application and the issue of meeting noise targets at Hunts Grove continues to be under contention. **Hardwicke Parish Council therefore requests that the Planning Authority rejects the application.**